TRIDONIC

Emergency lighting units EM powerLED

EM powerLED NM BASIC 1 W

Emergency lighting LED Driver 1 W

Product description

- Emergency lighting LED Driver for manual testing
- Non maintained operation
- SELV for output voltage < 60 V DC
- Low-profile casing (21 x 30 mm cross-section)
- 5-year guarantee

Properties

- Constant current mode
- With either screw or clip fastening (Clip-fix)
- 3 h rated duration
- Green charge status display LED
- Electronic charge system
- SELV (outputs powerLED, battery, status LED, test switch)
- Polarity reversal protection for battery
- Deep discharge protection
- Very low energy consumption from the battery after activation of the deep discharge protection
- Short-circuit-proof battery connection
- Emergency lighting LEDs available
- Optional test switch



Screw fastening



Clip fastening

Batteries

- High-temperature cells
- NiMH / NiCd batteries
- Cs cells
- 4-year design life
- 1-year guarantee
- For battery compatibility refer to table "Battery selection"



Standards, page 4


Wiring diagrams and installation examples, page 4

TRIDONIC


Emergency lighting units EM powerLED

EM powerLED NM BASIC 1 W

Emergency lighting LED Driver 1 W



Screw fastening



Clip fastening

Technical data

Rated supply voltage	220 – 240 V
Mains frequency	50 / 60 Hz
Typ. λ (at 230 V, 50 Hz, normal operation)	0.4c
Mains current	15 mA
Mains power in charging operation	1.3 W
Forward voltage range LED module	2.8 – 3.4 V
LED current in emergency operation	320 mA
Time to light	0.43 s from detection of emergency event
Overvoltage protection	320 V (for 1 h)
Battery charging time	24 h
Charge current	120 mA
Battery discharge current	See page 4
Number of cells	3
Ambient temperature ta	0 +60 °C
Max. casing temperature tc	70 ℃
Mains voltage changeover threshold	according to EN 60598-2-22
Type of protection	IP20

Ordering data

Туре	Article numbe	Packaging,	Packaging,	Weight	Max. number	Wattage
1990	Ameremaniber	carton	pallet	per pc.	of LEDs	wanage
Screw fastening version						
EM powerLED NM 1W BASIC	89800112	25 pc(s).	1,200 pc(s).	0.05 kg	1	1 W
Clip fastening version						
EM powerLED NM 1W BASIC	89800111	25 pc(s).	1,200 pc(s).	0.05 kg	1	1 W

Emergency lighting units EM powerLED



Test switch EM2

Product description

- For connection to the emergency lighting unit
- For checking the device function



Ordering data

Туре	Article number	Packaging, bag	Packaging, carton	Weight per pc.	
Test switch EM 2	89805277	25 pc(s).	600 pc(s).	0.011 kg	



Status indication green LED

Product description

• A green LED indicates that charging current is flowing into the battery



Ordering data

Туре	Article number	Packaging, bag	Packaging, carton	Weight per pc.
LED EM green	89899605	25 pc(s).	200 pc(s).	0.017 kg
LED EM green, ultra high brightness	89899756	25 pc(s).	200 pc(s).	0.012 kg

Emergency lighting units EM powerLED

1. Standards

according to EN 60598-2-22 according to EN 50172 EN 61347-2-7 EN 61347-2-13 EN 62384 EN 61547 EN 55015 EN 61000-3-2 EN 60068-2-29 EN 60068-2-30 EN 60068-2-64

1.1 Glow-wire test

according to EN 60598-1 with increased temperature of 850 °C passed.

1.2 Isolation and electric strength testing of luminaires

Electronic LED Driver can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an isolation test with 500 Vpc for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal. The isolation resistance must be at least 2 M Ω .

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1,500 Vac (or 1,414 \times 1,500 Vbc). To avoid damage to the electronic devices this test **must not be conducted**.


2. Thermal data

2.1 Expected life-time

Average life-time 50,000 hours under rated conditions with a failure rate of less than 10 %. Average failure rate of 0.2 % per 1000 operating hours.

3. Installation / Wiring

3.1 Wiring diagrams




Take care that the LED is connected with the right polarity. LED that are connected to the EM powerLED devices should have a reverse polarity protection device such as a schottky diodes fitted, otherwise irreversible damage could occur if the LED is connected in reverse polarity. Any protection device must be capaple of handling in excess of 700 mA.

Note: The Tridonic Emergency-LED is therefore fitted with a protection diode across the powerLED.

Note for manually tested emergency lighting with combined LED modules:

Due to the fact that independent circuits are used for normal and emergency lighting it is important that the normal supply of the mains LED Driver is switched off together with the permanent emergency supply prior to checking the operation of the emergency LEDs.

If this is not done then it may not be possible to see that the emergency LEDs are operating. Use a circuit similar to that shown next.




* Use 230 V Test switch

3.2 Wiring type and cross section

The wiring can be in stranded wire or solid. Strip 8.5–9.5 mm of insulation from the cables to ensure perfect operation of the push-wire terminals.

Wiring

mains (N, L)



Wiring

LED

batteries (Bat +, Bat –) test switch (switch) status indication LED (status K, A) LED (LED+, LED-)

wire preparation: 0.4 – 0.8 mm²
85_05mm

Max. lead insulation diameter				
Battery	2.1 mm			
Test switch	2.1 mm			
Indicator LED	2.1 mm			


2.1 mm

Maximum	lead	lenath
I'luxillualli	icuu	lengin

LED	3 m
status indication LED	1 m
batteries	1m

3.3 Release of the wiring

Press down the "push button" and remove the cable from front.



3.4 Wiring instructions


- The EM powerLED terminals, battery, indicator LED and test switch terminals are classified as SELV. Keep the wiring of the input terminals separated from the wiring of the SELV terminals or consider special wiring (double insulation, 6 mm creepage and clearance) when these connections should be kept SELV.
- EM powerLED leads should be separated from the mains connections and wiring for good EMC performance.
- Maximum lead length on the EM powerLED terminals is 3 m. For a good EMC performance keep the LED wiring as short as possible.
- Maximum lead length for the Test switch and Indicator LED connection is 1m. The test switch and Indicator LED wiring should be separated from the EM powerLED leads to prevent noise coupling.
- Battery leads are specified with 0.5 $\rm mm^2\, cross\, section$ and a length of < 1 m

4. Mechanical data

4.1 Housing properties

- Polycarbonat white
- Type of protection IP 20

4.2 Recommended fixing details for clip fixing



4.2 Mechanical data accessories

LED status indicator

- Green
- Mounting hole 6.5 mm dia
- Lead length 1000 mm

Test switch

- Mounting hole 7.0 mm dia
- Lead length 550 mm

Battery leads

- Quantity: 1 red and 1 black
- Length: 1 m
- Wire type: 0.5 mm² solid conductor
- Insulation rating: 90 °C

Battery end termination Push on 4.8 mm receptacle to suit battery spade fitted with insulating cover

Module end termination 8.0 mm stripped insulation

Two-piece batteries are supplied with a 200 mm lead with 4.8 mm receptacles at each end and insulating covers to connect the separate sticks together.

5. Electrical data

5.1 Maximum loading of automatic circuit breakers

Automatic circuit breaker type	B10	C10	B13	C13	B16	C16	B20	C20	Inrush	current
Installation Ø	1.5 mm ²	1.5 mm ²	1.5 mm ²	1.5 mm ²	2.5 mm ²	2.5 mm ²	2.5 mm ²	2.5 mm ²	 max	time
EM powerLED NM 1W BASIC	90	180	130	260	130	260	130	260	10 A	120 µs

6. Battery data

6.1 Battery selection

			EM powerLED NM 1	W BASIC, 3 h	
				Туре	EM powerLED NM 1W BASIC
				Article no.	89800111, 89800112
				Duration	3 h
				Cells	3 cells
Technology and capacity	Design	Number of cells	Туре	Article no.	Assignable batteries
NiCd 1,6 Ah Cs cells [®]	stick	1 x 3	Accu-NiCd C 3A	89899743	•
NIGU 1,0 AIT OS CEIIS-	battery pack	3	Pack-NiCd	89899676	•
NiMh 2 Ah Cs cells	stick	1 x 3	Accu-NiMh C 3A	89899744	•
· · · · ·					

[®] 50°C batteries also available (see seperate datasheet at www.tridonic.com)

8.2 Battery charge / discharge

EM powerLED NM 1W BASIC, 3 h

Туре	EM powerLED NM 1W BASIC				
Article no.	89800111, 89800112				
Duration	3 h				
Cells	3 cells				
Battery charge time	24 h				
Charge current	120 mA				
Discharge	350 mA at typ. LED forward voltage				
Discharge current	375 mA at max. 3.4 V LED forward voltage				

6.3 Accu-NiCd

Battery voltage/cell	1.2 V
Cell type	Cs
Case temperature range	
to ensure 4 years design life	+5 °C to +50 °C
Max. short term temperature (reduced life-time)	70 °C
Max. number discharge cycles	4 cycles per year plus 4 cycles during comissioning
Max. storage time	6 months
6.4 Accu-NiMh	
2.0 Ah	
Battery voltage/cell	1.2 V
Cell type	Cs
Case temperature range	
to ensure 4 years design life	+5 °C to +55 °C
Max. short term temperature (reduced life-time)	70 °C
	10 0
Max. number discharge cycles	4 cycles per year plus 30 cycles during comissioning
	4 cycles per year plus 30 cycles during

6.5 Wiring batteries

Connection method: 4.8 x 0.5 mm spade tag welded to end of cell

For stick packs this connection is accessible after the battery caps have been fitted.

To inhibit inverter operation disconnect the batteries by removing the connector from the battery spade tag.

For further information refer to corresponding battery datasheet.

6.6 Storage, installation and commissioning

Relevant information about storage conditions, installation and commissioning are provided in the battery datasheets.

7. Miscellaneous

7.1 Additional information

Additional technical information at $\underline{www.tridonic.com} \rightarrow \text{Technical Data}$

Guarantee conditions at <u>www.tridonic.com</u> \rightarrow Services

Life-time declarations are informative and represent no warranty claim. No warranty if device was opened.